


FIRE DEPARTMENT STAGING AREA (LEVEL AREAS)



- LEGEND**
- Project Site Boundary
 - Existing Topographic Contour
 - Proposed Post-Project Topographic Contour
 - Proposed Roadway/Parking
 - Proposed Hotel/Secondary Hotel Building
 - Existing Fire Hydrant
 - Proposed Fire Hydrant
 - Proposed Fire Lane
 - Areas Not Modified by Fuel Modification Plan; species composition may change due to dispersal of waste water
- Fuel Modification Zones**
- Zone A (Setback Zone)
Inherently highly fire resistant plants, spaced appropriately. Plants shall not be allowed within 30' or more of combustible structures.
 - Zone B (Irrigated Zone)
Landscaping and vegetation shall typically consist primarily of green lawns and ground covers, and shrubs and trees. Plants shall be fire resistant and spaced adequately.
 - Zone C (Native Brush Thinning Zone)
Native vegetation shall be modified by thinning and removal of species constituting a high fire risk, including coastal sage scrub. Any additional planted species shall be fire resistant and spaced adequately.

